



Umrechnung von ppm in mg/kWh

(G) HANS G. WERNER GmbH REUTLINGEN

O ₂ 4.5% = CO ₂ 12.01%		O ₂ 3.0% = CO ₂ 13.10%		O ₂ 2.4% = CO ₂ 13.54%	
NOX Faktor: 2.32		NOX Faktor: 2.14		NOX Faktor: 2.06	
ppm	mg/kWh	ppm	mg/kWh	ppm	mg/kWh
30	69.6	30	64.2	30	61.8
31	71.9	31	66.3	31	63.8
32	74.2	32	68.5	32	65.9
33	76.5	33	70.6	33	68
34	78.9	34	72.7	34	70
35	81.2	35	74.9	35	72.1
36	83.5	36	77	36	74.1
37	85.8	37	79.2	37	76.2
38	88.1	38	81.3	38	78.3
39	90.5	39	83.4	39	80.3
40	92.8	40	85.6	40	82.4
41	95.1	41	87.7	41	84.4
42	97.4	42	89.9	42	86.5
43	99.7	43	92	43	88.6
44	102.1	44	94.1	44	90.6
45	104.4	45	96.3	45	92.7
46	106.7	46	98.4	46	94.7
47	109.0	47	100.6	47	96.8
48	111.3	48	102.7	48	98.9
49	113.7	49	104.8	49	100.9
50	116	50	107	50	103
51	118.3	51	109.1	51	105
52	120.6	52	111.3	52	107.1
53	122.9	53	113.4	53	109.2
54	125.2	54	115.5	54	111.2
55	127.6	55	117.7	55	113.3
56	129.9	56	119.8	56	115.3
57	132.2	57	122	57	117.4
58	134.5	58	124.1	58	119.5
59	136.9	59	126.2	59	121.5
60	139.2	60	128.4	60	123.6
61	141.5	61	130.5	61	125.6
62	143.8	62	132.7	62	127.7
63	146.1	63	134.8	63	129.8
64	148.5	64	136.9	64	131.8
65	150.8	65	139.1	65	133.9
66	153.1	66	141.2	66	135.9
67	155.4	67	143.4	67	138
68	157.7	68	145.5	68	140.1
69	160.1	69	147.6	69	142.1
70	162.4	70	149.8	70	144.2